



COMMERCIAL PRODUCTS

SECTION 05 73 00 DECORATIVE METAL RAILINGS **Summit™ Modular Railing System**

PART 1 GENERAL

1.01 WORK INCLUDED

- A. Furnish and/or install supported glass stainless steel railings, glass and components.

1.02 REFERENCE

A. American National Standards Institute (ANSI)

1. A17.1 Accessible and Usable Buildings and Facilities.
2. A21.1 Safety Requirements for Floor and Wall Openings, Railings and Toe Boards.
3. A58.1 Minimum Design Loads in Buildings and Other Structures.
4. Z97.1 Safety Performance Specifications and Methods of Test for Safety Glazing Materials Used in Buildings.

B. American Society for Testing and Materials (ASTM)

1. A555 - Standard Specification for General Requirements for Stainless Steel Wire and Wire Rods.
2. A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.
3. C1048 - Standard Specification for Heat-Treated Flat Glass - Hind HS, Kind FT Coated and Uncoated Glass.
4. E 894 - Standard Test Method for Anchorage of Permanent Metal Railing Systems and Rails for Buildings.
5. E 935 - Standard Test Methods for Performance of Permanent Metal Railing Systems and Rails for Buildings.
6. E 985 - Standard Specification for Permanent Metal Railing Systems and Rails for Buildings.
7. E 2358 – Standard Specification for the performance in permanent glass railings,

guards and balustrades.

- C. Americans with Disabilities Act Accessibility Guidelines (ADA).
- D. National Association of Architectural Metal Manufacturers (NAAMM)
 - 1. Metal Finishes Manual.
 - 2. Pipe Railing Manual.
 - 3. Stair Manual.

1.03 STRUCTURAL REQUIREMENTS

A. Structural Performance: Provide handrails and railings capable of withstanding the following structural loads without exceeding allowable design working stress of materials for handrails, railings, anchors and connections:

1. Top Rail of Guards: Shall withstand the following loads:

- a. Concentrated load of 200 lbf (0.899kN) applied at any point and in any direction.
- b. Uniform load of 50 lbf-ft. (0.07kN-m) applied horizontally and concurrently with uniform load of 100 lbf-ft. (0.14kN-m) applied vertically downward.
- c. Concentrated and uniform loads above need not to be assumed to act concurrently.

2. Handrails Not Serving As Top Rails: Shall withstand the following loads:

- a. Concentrated load of 200 lbf (0.89kN) applied at any point and in any direction.
- b. Uniform load of 50 lbf-ft. (0.07kN-m) applied in any direction.
- c. Concentrated and uniform loads above need not be assumed to act concurrently.

3. Guards Infill Area: Shall withstand the following loads;

- a. Concentrated horizontal load of 200 lbf (0.89kN) applied to a 1sq. ft. at any point in system, including panels, intermediate rails, balusters, or other elements composing infill area. Loads need not to be assumed to act concurrently, with loads on top rails in determining stress on guard.

B. Thermal Movements: Design handrails and railings to allow for movements resulting from 120 degree F (49 C) changes in ambient and 180 degree F (82 C) surface temperatures. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.

C. Corrosion Resistance: Separate incompatible materials to prevent galvanic corrosion.

1.04 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer to submit approval drawings to include the following:
 - 1. Section details.
 - 2. Mounting methods.
 - 3. Typical Elevations.
 - 4. Key plan layouts
- C. Shop Drawings: Drawings showing fabrication and installation of handrails including plans, elevations, sections, details of components, anchor details, and attachment to adjoining units of work.

1.05 QUALITY ASSURANCE

- A. Source Limitations: Trex Commercial Products, 7008 Northland Drive North, Suite 150; Minneapolis, MN 55428; Toll Free Tel: 877-215-RAIL(7245); Email: info@trexcommercial.com.
- B. Manufacturer Qualifications: All primary productions specified in this section will be supplied by a single manufacturer with a minimum of five (5) years of experience.
- C. Railing System:
 - 1. System components: Pre-engineered, designed by licensed Professional Structural Engineer.
 - 2. Attachments to building structure: Designed by Professional Structural Engineer licensed in State in which project is located.
- D. Perform Work in accordance with ASTM #985.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Materials to be delivered to the job site in good condition and adequately protected against damage as handrails are a finished product.
- B. Store on site in a location and manner to avoid damage. Stacking should be done in a manner that will prevent bending. Store material in a clean, dry location away from uncured concrete and masonry. Any protection on the railings during transportation should remain until installed.
- C. Keep handling on site to a minimum. Exercise caution to avoid damage to finishes of material.

1.07 PROJECT CONDITIONS

- A. Field Measurements: Where handrails and railings are indicated to fit to other construction, check actual dimensions of other construction by accurate field measurements before fabrication.
- B. Where field measurements cannot be made without delaying the railing fabrication and delivery, obtain guaranteed dimensions in writing by the Contractor and proceed with fabrication of products to not delay fabrication, delivery and installation.
- C. Coordinate fabrication and delivery schedule of handrails with construction progress and sequence to avoid delay of railing installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Acceptable Manufacturer: Trex Commercial Products, 7008 Northland Drive North, Suite 150; Minneapolis, MN 55428; Toll Free Tel; 877-215-RAIL(7245); Email; info@trexcommercial.com.

2.02 MATERIALS AND FINISHES

Materials

- A. Stainless Steel bar post to be 304 or 316 2" x 5/8" stainless steel flat bar - with a #6 polish.
- B. All fittings to be 304 or 316 stainless steel. Post side glass clips will be used to support glass
- C. Glass: 9/16" clear laminated glass with beveled edges and all exposed edges ground smooth and polished.
- D. Glass infill shall be offset from post-to-post centerline by use of point supported disks and rods or on centerline of post if using glass clamps.
- E. Specify top rail as: 2 1/2" stainless steel or 2 1/2" wood using hard maple, oak, and cherry per sections detailed. All wood finishes being by others to facilitate matching of finishes.
- F. Grip rail to be 1 1/2" O.D. stainless steel.

Finishes

- A. All stainless steel pipe and tubing to receive a #6 polish.

2.03 FASTENERS

- A. All mechanical fasteners used shall be manufactured from stainless steel.

2.04 FABRICATION

- A. All mitered and welded corners shall be ground smooth to match finish.
- B. Make exposed joints butt tight and flush.
- C. Interior sleeves shall be used for typical splices.
- D. Fasteners are allowed at splice connection.
- E. Verify dimensions on site prior to shop fabrication.

PART 3 EXECUTION

3.01 PREPARATION

- A. Coordinate post setting drawings, diagrams, templates, instructions, and directions for installation of anchorages. These include items such as sleeves, concrete inserts, anchor bolts, and miscellaneous items having integral anchors that are to be embedded in concrete and masonry construction.

1. Coordinate delivery of anchorages to project site.
 2. Coordinate that blocking is in place for all mounting fasteners.
- B. Clean debris and dust from surfaces and embed holes thoroughly prior to installation.
- C. Prepare surfaces using the methods recommended by the manufacturer for achieving proper results given the substrate and project conditions.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's drawings and direction.
- B. Fit exposed connections accurately together to form tight joints except as necessary for expansion.
- C. Perform cutting, drilling, and fitting required for installation of handrails. Accurately set handrails in location, alignment, and elevation, measured from established lines and levels.
- D. Set posts plumb within a tolerance of 1/8 inch (3 mm).
- E. When fastening to in-place construction, provide anchorage devices and fittings to properly secure rail to in-place construction. Examples of such devices include threaded fittings (for concrete inserts), toggle bolts and through-bolts. Separate dissimilar materials with bushings, grommets or washers to prevent electrolytic corrosion.

3.02 PROTECTION

- A. Upon delivery railing may have protective wrapping. At completion of railing installation, immediately remove any protective wrapping and clean all work for inspection and approval.
- B. After installation, General Contractor or Owner shall be responsible for protection of railings during the balance of construction.
- C. When cleaning stainless steel surfaces use plain water containing a mild soap or detergent. No abrasive agents or harsh chemicals shall be used.

END OF SECTION